



# Certificate of Compliance

No. 0D201218.CEAWT12

Certificate's  
Holder:

«Cheboksary Electric Apparatus  
Plant», AO (CHEAZ, AO)  
428020, Russian Federation, Chuvash Republic,  
Cheboksary, I. Y. Yakovlev pr., 5

Certification ECM  
Mark:



Product:  
Brand:  
Model(s):

Air Circuit Breaker  
CHEAZ  
(see the following annex)

Verification to:

Standard:  
EN 60947-1:2007/A2:2014,  
EN 60947-2:2017/A1:2020,  
EN 60947-3:2009/A1:2012

related to CE Directive(s):  
2014/35/EU (Low Voltage)  
2014/30/EU (Electromagnetic Compatibility)

Remark: This document has been issued on a voluntary basis and upon request of the manufacturer. It is our opinion that the technical documentation received from the manufacturer is satisfactory for the requirements of the ECM Certification Mark. The conformity mark above can be affixed on the products accordingly to the ECM regulation about its release and its use.

Additional information and clarification about the Marking:



The manufacturer is responsible for the CE Marking process, and if necessary, must refer to a Notified Body. This document has been issued on the basis of the regulation on ECM Voluntary Mark for the certification of products. RG01\_ECM rev.3 available at: [www.entecerma.it](http://www.entecerma.it)

Issuance date: 18 December 2020

Expiry date: 17 December 2025

Reviewer  
Technical expert  
Amanda Payne

Approver  
ECM Service Director  
Luca Bedonni

Ente Certificazione Macchine Srl

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY

+39 051 6705141 +39 051 6705156 info@entecerma.it www.entecerma.it

# Annex I

No. 0D201218.CEAWT12



Model(s):

ACBs BA50-47 (EN, EA, ER, EP, EQ, EG) 200, 400, 630, 1000, 1250, 1600, 2000, 2500, 4000, 5000, 6300 A: M, H, S.

