

Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report № 015.12CV-20 Page 1, total amount:26



Barnash A.

TESTING LABORATORY (TL) Tel. +38(050) 75005 q7 E-mail: nvkzp@ukr.net

Approved by Director of RMC "Test center"

Issued Date: 14

		TEST REPORT
		№ 015.12CV-20
Testing laboratory T	L RMC "Test cent	er" tests were carried out by:
	ACBs BA	50-47 4000H40 3H M11C11S11 39U00
	all and the second seco	(Product Type:)
The Applicant of		ectric Apparatus Plant», AO
tests:	CHEAZ, AO	
	428020, Russian	Federation, Chuvash Republic, Cheboksary, I. Y. Yakovlev pr., 5
Brand;		CHEAZ
Models:		
Factory number:		
Manufacturer:		«Cheboksary Electric Apparatus Plant», AO
		CHEAZ, AO
		428020, Russian Federation, Chuvash Republic, Cheboksary, I.
		Y.Yakovlev pr., 5

1. CHARACTERISTIC OF TESTS	
1.1.	
Test work started:	01.12.2020
Test work completed:	14.12.2020
2 Actual address of the testing laboratory:	Testing laboratory RESEARCH AND
3	MANUFACTURING COMPLEX
	"TEST CENTER" (RMC, Address: 69096,
	c.Zaporizhzhia, str. Borodinska, 108

1.3 Applied standards:

EN 60947-1:2007/A2:2014 «Low-voltage switchgear and controlgear. General rules»;

EN 60947-2:2017/A1:2020 «Low-voltage switchgear and controlgear. Circuit-breakers»;

EN 60947-3:2009/A1:2012 «Low-voltage switchgear and controlgear. Switches, disconnectors, switch-disconnectors and fuse-combination units».

2. Test conditions:	
- Temperature, °C:	21
- Relative humidity, %:	48
- Atmospheric pressure, kPa:	102

3. Testing equipment according to laboratory data sheet of Testing and Measuring equipment have actual terms of stamps of calibration seals, licences and certificates.



RESEARCH AND MANUFACTURING COMPLEX

"TEST CENTER" (RMC "Test center")
Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032
Actual address: 69096, c.Zaporizhzhia, str. Borodinska, 108

Test report № 015.12CV-20 Page 2, total amount:26

4. RESULTS OF THE TESTS				
Requirement - Test	Clause	Result - Remark	Verdict	
	2	3	4	
EN 60947-1:2007/A2:2014, EN 6		017VA1:2020, EN 6	0947-3:2009/A1:2012	
Constructional and performance	7			
requirements				
Constructional requirements	7.1			
Materials	7.1.2			
General materials requirements The manufacturer shall specify which test method, 7.1.2.2 or 7.1.2.3, is to be used. Parts of insulating materials which might be exposed to thermal stresses due to electrical effects within the equipment shall not be adversely affected by abnormal heat and by fire	7.1.2.			P
affected by abnormal heat and by fire.	7.1.3			P
Current-carrying parts and their connections Current-carrying parts shall have the necessary mechanical strength and current-carrying capacity for their intended use. For electrical connections, no contact pressure shall be transmitted through insulating material other than ceramic or other material with characteristics not less suitable, unless there is sufficient resiliency in the metallic parts to compensate for any possible shrinkage or yielding of the insulation material. Compliance shall be verified by inspection and by conducting the test sequences according to the relevant product standard.				1
Terminals	7.1.8			
Constructional requirements All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength. Terminal connections shall be such that the force to connect the conductors may be applied by screws, screwless-type or other quivalent means so as to ensure that the necessary contact pressure is maintainet. Terminals shall be so constructed that	7.1.8.			P



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 3, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
the conductors can be clamped between			, cruict
suitable surfaces without any significant			
damage either to conductors or			
terminals.			
Terminals shall not allow the			
conductors to be displaced or be			
displaced themselves in a manner			
detrimental to the operation of			
equipment and the insulation voltage			
shall not be reduced below the rated			
values.			
If required by the application, terminals			
and conductors may be connected by			
means of cable lugs for copper			
conductors only.			
Screwless-type clamping units, unless			
otherwise specified by the			
manufacturer, shall accept rigid and			
flexible conductors as indicated in			
Table 1.			
On screwless-type clamping unit, the			
connection or disconnection of			
conductors shall be made as follows:			
on universal clamping units by the use			
of a general purpose tool or a			
convenient device, integral with the			
clamping unit to open it for the insertion			
or withdrawal of the conductors;			
on push-wire clamping units by			
simple insertion. For the disconnection			
of the conductors an operation other			
than a pull only on the conductor shall			
be necessary. The use of a general			
purpose tool or of a convenient device,			
integral with the clamping unit is			
allowed in order to "open" it and to			
assist the insertion or the withdrawal of the conductor.			
	i i		
Examples of terminals are given in Annex D.			
The requirements of this subclause shall be verified by the tests of 8.2.4.2,			
8.2.4.3 and 8.2.4.4, as applicable.	710		
Connecting capacity The manufacturer shall state the type	7.1.8.		P
The manufacturer shall state the type (rigid – solid or stranded – or flexible),	2		
the minimum and the maximum cross-			
sections of conductors for which the			
The test results contained in this report relates	1 2 4		



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 4, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
terminal is suitable and, if applicable,				
the number of conductors				
simultaneously connectable to the				
terminal. However, the maximum cross-				
section shall not be smaller than that				
stated in 8.3.3.3 for the temperature-rise				
test and the terminal shall be suitable				
for conductors of the same type (rigid –				
solid or stranded – or flexible) at least				
two sizes smaller, as given in the				
appropriate column of Table 1.				
Connection	7.1.8.	(4		P
Terminals for connection to external	3			
conductors shall be readily accessible				
during installation.				
Clamping screws and nuts shall not				
serve to fix any other component				
although they may hold the terminals in				
place or prevent them from turning.				
Terminal identification and marking	7.1.8.	_		P
Terminals shall be clearly and	4			
permanently identified in accordance				
with IEC 60445 and Annex L, unless				
superseded by the requirements of the				
relevant product standard.				
Terminal connections shall be such that				
the force to connect the conductors may				
be applied by screws, screwless-type or				
other equivalent means so as to ensure				
that the necessary contact pressure is				
maintained.				
Screwless-type clamping units, unless				
otherwise specified by the				
manufacturer, shall accept rigid and flexible conductors as indicated in				
Table 1.				
On screwless-type clamping unit, the				
connection or disconnection of				
conductors shall be made as follows:				
on universal clamping units by the use				
of a general purpose tool or a				
convenient device, integral with the				
clamping unit to open it for the insertion				
or withdrawal of the conductors;				
on push-wire clamping units by				
simple insertion. For the disconnection				1
of the conductors				
an operation other than a pull only on				
The test results contained in this report relate	only to the I	tom(a) tagted. Total or mortial a	anvina a Ctart	



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 5, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
the conductor shall be necessary. The			
use of a general purpose tool or of a			
convenient device, integral with the			
clamping unit is allowed in order to			
"open" it and to assist the insertion or			
the withdrawal of the conductor.			
Terminals intended exclusively for the			
neutral conductor shall be identified by			
the letter "N", in accordance with IEC			
60445.			
The protective earth terminal shall be			
identified in accordance with 7.1.10			
Provisions for protective earthing	7.1.10		
Constructional requirements	7.1.10		P
The exposed conductive parts (e.g.	.1		
chassis, framework and fixed parts of			
metal enclosures) other than those			
which cannot constitute a danger shall			
be electrically interconnected and			
connected to a protective earth terminal			
for connection to an earth electrode or			
to an external			
protective conductor.			
This requirement can be met by the			
normal structural parts providing			
adequate electrical continuity and			
applies whether the equipment is used			
on its own or incorporated in an			
assembly.			
Exposed conductive parts are			
considered not to constitute a danger if			
they cannot be touched on large areas or			
grasped with the hand or if they are of			
small size (approximately $50 \text{ mm} \times 50$			1
mm) or are so located as to exclude any			
contact with live parts.			
Examples of these are screws, rivets,			
nameplates, transformer cores,			
electromagnets of switching devices and			
certain parts of releases, irrespective of			
their size.	7110		
Protective earth terminal	7.1.10	(1 00	P
The protective earth terminal shall be	.2		
readily accessible and so placed that the			
connection of the equipment to the earth			
electrode or to the protective conductor			
is maintained when the cover or any			



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 6, total amount:26

Requirement - Test	Clause	Result - Remark		Verdict	
other removable part is removed.			•		
The protective earth terminal shall be					
suitably protected against corrosion.					
In the case of equipment with					
conductive structures, enclosures, etc.,					
means shall be provided, if necessary, to					
ensure electrical continuity between the					
exposed conductive parts of the					
equipment and the metal sheathing of					
connecting conductors.					
The protective earth terminal shall have					
no other function, except when it is					
intended to be connected to a PEN					
conductor (see 2.1.15 – Note). In this				- 1	
case, it shall also have the function of a					
neutral terminal in addition to meeting					
the requirements applicable to the					
protective earth terminal.					
Protective earth terminal marking	7.1.10		_		P
and identification	.3				
The protective earth terminal shall be					
clearly and permanently identified by its					
marking.					
The identification shall be achieved by					
colour (green-yellow mark) or by the				3	
notation PE, or PEN, as applicable, in	- 1				
accordance with IEC 60445, subclause				1	
5.3, or by a graphical symbol for use on					
equipment.				4	
The graphical symbol to be used is the					
symbol:					
2 -IEC-5019 Protective earth					
(ground)					
in accordiance with IEC 60417-2.					
General performance characteristics	8.3.3				
Sample number			#001		
Rated current: In (A)		4	4000		
Rated operational voltage: Ue (V)		A	.C440		
Rated control supply voltage of					
secondary circuits: Uc (V)		A	.C230		
Value of tripping current declared by					
the manufacturer for a single pole, at					
which value they shall operate:		4k A	~80kA		
Range of adjustable setting current			~80kA		
Tripping under short-circuit	8.3.3.	1162			
conditions	1				



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 7, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
Opening under short-circuit	8.3.3.			
conditions	1.2			
Test current 85% of the rated, or				
minimum adjustable setting current (A	A):	34	100	
Operating time >0.2s in case of				
instantaneous releases (s): L1-L	2.	>	0,2	
L1-L	3:		0,2	P
$\overline{ ext{L2-L}}$	3:		0,2	
Test current 85% of the rated, or				
maximum adjustable setting current	ŧ			
(A):		68	000	
Operating time >0,2s in case of				
instantaneous releases (s)				
L1-L	2:	>(0,2	P
L1-L	3:		0,2	
L2-L		1	0,2	
Test current 115% of the rated, or			- ,	
minimum adjustable setting current (A	v):	46	500	
Operating time < 0.2s in case of				
instantaneous releases (s):	2	0.0	024	
L1-L: L1-L:	2:	1	022	P
L2-L		1	022	1
Test current 115% of the rated, or	·	1,1		
maximum adjustable setting current		92	000	
(A): Operating time <0.2s in case of		72		
instantaneous releases (s):		a		
L1-L2	2:	1	024	
L1-L3	3:		023	P
L2-L3	200)21	
Test current: tripping current declared for single pole operation (A):		4600/	92000	
Operating time < 0,2s in case of		4600 A	92000 A	
instantaneous release (s):		0,026	0,027	
L	1:	0,024	0,025	P
r.	2: 3:	0,023	0,023	
Test current: 80% of the rated, or		Instantaneous: 3,2 k		
minimum adjustable setting current:		Definite time delay:		
Operating time: >0,2s in case of		Z Jimite time delay.	120011	
instantaneous releases:				
	.1:	0,442 s		P
	2:	0,455 s		1
	3:	0,431 s		
Operating time: > twice time delay		0,1010		
stated by the manufacturer, in the case				
of definite time delay releases:	-	Time de	lay 0,1 s:	
·	1:	0,288 s	wy Ogi D.	I

The test results contained in this report relate only to the Item(s) tested. Total or partial copying of test report is forbidden without permition of

Testing laboratory RMC "Test center".



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 8, total amount:26

Requirement - Test		Clause	Result - Remark	Verdict	
	L2:		0,332 s		
	L3:		0,321 s		
Test current: 120% of the rated, or			Instantaneous: 4,8 kA		
minimum adjustable setting current:			Definite time delay		
Operating time: <0,2s in case of				,	
instantaneous releases:					
	L1:		0,033 s		P
	L2:		0,026 s		
	L3:		0,036 s		
Operating time: < twice time delay					
stated by the manufacturer, in the ca	se .		-		
of definite time delay releases:			Time de	elay 0,1 s:	
• •	L1:		0,021 s	- x - x - x - x - x - x - x - x - x - x	P
	L2:		0,022 s		1
	L3:		0,022 s		
Test current: 80% of the maximum			Definite time delay	: 48 kA	
adjustable setting current:					
Operating time: > twice time delay					
stated by the manufacturer, in the ca	se.				
of definite time delay releases:	50		Time de	elay 0,4 s:	P
or definite time delay releases.	L1:		0,891 s	лау 0,4 з.	1
	L2:		0,887 s		
	L3:		0,852 s		
Test current: 120% of the maximum			Definite time delay	· 72 1 ₂ A	
adjustable setting current:	E:		Definite time delay	. /2 KA	
Operating time: < twice time delay					-
stated by the manufacturer, in the ca	0.0				
of definite time delay releases:	SC		Time de	10xx 0 4 a.	
of definite time delay feleases.	L1:			elay 0,4 s:	
	L1:		0,445 s		P
	L2. L3:		0,448 s		
Opening under everled condition		022	0,431 s		
Opening under overload condition	S	8.3.3. 1.3			
b) Inverse time delay releases		1.5			
Test current: 105% of the rated, or	-				
,			17	00 4	
minimum adjustable setting current:				80 A	-
Conventional non-tripping time 2h			t1=15s 3h 16 min	t2=480s 3h 22 min	P
Test current: 130% of the rated, or					
minimum adjustable setting current:			208	80 A	
Conventional tripping time < 2h			t1=15s	t2=480s	P
			1h 2 s	1h 11 s	
Test current: 105% of the maximum					
adjustable setting current:			420	00 A	
Conventional non-tripping time 2h			t1=15s	t2=480s	P



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 9, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
		2h 48 min	3h 32 min	
Test current: 130% of the maximum				
adjustable setting current:	June 15 T	5200	0 A	
Conventional tripping time < 2h		t1=15s	t2 = 480s	P
		1h 12 s	1h 1 min	
An additional test, at a current				
specified by the manufacturer to verify				
the time/current characteristic of the				
releases conform to the curves provided				
by the manufacturer				
Test current specified by the				
manufacturer at maximum adjustable		220) A	
setting current:		3200	J A	
Tripping time according time/current characteristic of the releases conform to				
the curves provided by the manufacturer				P
(within the stated tolerances)		t1=15s	t2=480s	r
L1-L2-L3:		8 s	241 s	
Additional test for definite time-delay	8.3.3.	0.5	2418	
releases	1.4			
a) Time delay				+
Overload release (all phases loaded)				
Test current: 1,5 times of the rated or				
minimum adjustable setting current:		2400) A	
Operating time between the limits stated			~ ~ ~	
by the manufacturer:		t1=48	80 s	P
L1-L2-L3:		365		1
Short-circuit release (two poles in series				
carrying the test current, using				
successively all possible combinations				
of poles having a short-circuit release)				
Test current: 1,5 times of the maximum				
adjustable setting current:		2160	0 A	
Operating time between the limits stated				
by the manufacturer:		t1=0,1s	t1 = 15s	
L1-L2:		0,102 s	0,417 s	P
L2-L3:		0,100 s	0,411 s	
L1-L3:		0,101 s	0,420 s	
b) Non-tripping duration				
Overload release (all phases loaded)				
Test current: 1,5 times of the rated or				
minimum adjustable setting current:		2400) A	
Time interval of non-tripping duration	1			
stated by the manufacturer:		56 s at	t1=60	



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 10, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
CB shall not trip after time interval of				
non-tripping duration stated by the				
manufacturer and after current is				
reduced to the rated current and				P
maintained at this value for twice the				
time-delay stated by the manufacturer:				
L1-L2-L3':		N	o trip	
Short-circuit release (two poles in series			*	
carrying the test current, using				
successively all possible combinations				
of poles having a short-circuit release)				
Test current: 1,5 times of the maximum				
adjustable setting current:		21	600 A	
Time interval of non-tripping duration				
stated by the manufacturer:		>=0.06 at t1=0,	1; $>=0.35$ at t2=0.4	
CB shall not trip after time interval of		. ,	,	
non-tripping duration stated by the				
manufacturer and after current is				
reduced to the rated current and				
maintained at this value for twice the				P
time-delay stated by the manufacturer:				
L1-L2:		N	o trip	
L2-L3:			o trip	
L1-L3:			o trip	
Test of dielectric properties, impulse	8.3.3.			
withstand voltage	2			
The 1,2/50µs impulse voltage shall be	8.3.3.			
applied 5 times fr each polarity at	4 part			
intervals of 1s minimum	1			
- rated impulse withstand voltage (kV):			12	
- sea level of the laboratory:		Sea	a level	
- test Uimp main circuits (kV):			14,8	
- test Uimp on open main contacts			,	
(equipment suitable for isolating) (kV):			18,5	
a) Application of test voltage			*	
i) Between all terminals of the main				
circuit connected together (incl. control				
and auxiliary circuits connected to the				
main circuit) and the enclosure or				P
mounting plate, with the contacts in al				
normal positions of operation.				
ii) Between all terminals of the main				
circuit and the other poles connected				
together and to the enclosure or				P
mounting plate, with the contacts in all				
S.F	1			1



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 11, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
normal positions of operation			
iii) Between each control and auxiliary			
circuit not normally connected to the			
main circuit and:			
- the main circuit			P
- other circuits			
- exposed conductive parts			
- enclosure of mounting plate			
iv) equipment suitable for isolation			
- no unintentional disruptive discharge			P
during tests			
Application of test voltage	8.3.3. 2.2		
a) 1) With circuit-breaker in the closed			
position			
- between all live parts of all poles			
connected together and the frame of the			P
circuit-breaker			
- between each pole and all the other	-		
poles connected to the frame f the			
circuit-breaker			
a) 2) With circuit-breaker in the open			
position and, additionally, in the tripped			
position, if any:			
- between all live parts of all poles			
connected together and the frame of the			P
circuit-breaker			
- between the terminals of one side			
connected together and the terminals of			
the other side connected together			
b) 1) Between all the control and			
auxiliary circuits which are not			n n
normally connected to the main circuit,			P
connected together, and the frame of the			
circuit-breaker			
b) 2) Where appropriate, between each			
part of the control and auxiliary circuits			D
which may be isolated from the other			P
parts during normal operation and all			
the other parts connected together	022	< 0.02	Α
For circuit-breaker suitable for	8.3.3.	< 0,03 r	mA
isolation, the leakage current shall be	4	-	TD.
measured through each pole with the			P
contacts in the open position, at a test			
voltage of 1,1 Ue and shall not exceed	<u> </u>		



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 12, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
0,5 mA		,	
Mechanical operation and	8.3.3.		
operational performance capability	3		
Construction and mechanical	8.3.3.		
operation	3.2		
a) Construction			
A withdrawable circuit-breaker shall be			
checked for the requirements stated in			P
7.1.1			_
A circuit-breaker with stored energy			
operation shall be checked for			1
compliance with 7 2.1.1.5. regarding the			P
charge indicator and the direction of			_
operation of manual energy storing			
b) Mechanical operation			
A circuit-breaker with stored energy			
operation shall comply with the			
requirements stated in 7.2.1.5 with the			
auxiliary supply voltage at 85% and			P
110% of the rated control supply			
voltage			
It shall also be verified that the moving			
contacts cannot be moved from the open			
position when the operating mechanism			P
is charged to slightly below the full			1
charge as evidenced by the indicating			
device			
For a trip-free circuit-breaker it shall not			
be possible to maintain the contacts in			
the touching or closed position when the			P
tripping release is in the position to trip			Г
the circuit-breaker			
c) Undervoltage releases			
Undervoltage releases shall comply			
with the requirements of 7.2.1.3 of Part			
1. For this purpose the release shall be			
fitted to a circuit-breaker having the			n
maximum current rating for which the			P
release is suitable			
i) Drop out voltage			
It shall be verified that the release			
operates to open the circuit-breaker			T.
between the voltage limits specified			P
The voltage shall be reduced from rated			
voltage at a rate to reach 0 V in			
voltage at a fate to feach U V III			P



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 13, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
approximately 30 s			
The test for the lower limit is made			
without current in the main circuit and			P
without previous heating of the release			1
coil			
In the case of a release with a range of			
rated voltages, this test applies to the			P
maximum voltage of the range			
The test for the upper limit is made			
starting from a constant temperature			
corresponding to the application of			P
rated control supply voltage to the			
release and rated current m the main			
poles of the circuit-breaker			
In the case of a release with a range of			
rated voltages, this test is made at both			
the minimum and maximum rated			P
control supply voltages			
ii) Test for limits of operation			
Starting with the circuit breaker open at			
the temperature of the test room, and			
with the supply voltage at 30% rated			
maximum control supply voltage, it			P
shall be verified that the circuit-breaker			1 20
cannot be closed by the operation of the			
actuator			
When the supply voltage is raised to			
85% of the minimum control supply			
voltage it shall be verified that the			P
circuit-breaker can be closed by the			100
operation of the actuator			
iii) Performance under overvoltage			
conditions			
With the circuit-breaker closed and			
without current in the main circuit. It			
shall be verified that the undervoltage			
release will withstand the application of	2		P
110% rated control supply voltage for 4			1
h without impairing its functions			
d) Shunt releases			
Shunt releases shall comply with the			
requirements of 7.2.1.4 of Part 1. For			
this purpose, the release shall be fitted			P
to a circuit-breaker having the			1
maximum rated current for which the			



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report № 015.12CV-20 Page 14, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
release is suitable			
It shall be verified that the release will			
operate to open the circuit-breaker at			
70% rated control supply voltage when			
tested at an ambient temperature of 55			P
$^{\circ}$ C ± 2 $^{\circ}$ C without current in the main			
poles of the circuit-breaker			
In the case of a release having a range			
of rated control supply voltages, the test			
voltage shall be 70% of the minimum rated control supply voltage			P
Operational performance capability	8.3.3.		
without current	3.3		#
Rated control supply voltage of shunt		AC230	
releases Uc (V)		<u> </u>	
Number of operating cycles per hour		10	
10% of total cycles for circuit-breaker with fitted shunt release energized at the rated Uc (50% at the beginning/50% at the end of the test):			
the rated Uc (50% at the beginning/50%			P
at the end of the test):		200/200	
Number of cycles without current, not including cycles made by shunt release		3600	P
Operational performance capability	8.3.3.		
with current	3.4		
Rated current (A)	3.1	4000	
Maximum rated operational voltage Ue		690	
(V)			
Number of operating cycles per hour		10	
Conditions, make/break operations: - test voltage U/Ue=1,0 (V)			
L1: L2:		692	
L3:		692	
- test current I/Ie=1,0 (A)		692	
L1: L2:		4000	
L3:		4000	
- power factor/time constant		4010 0,82	
- frequency (Hz) - on-time (ms)		50	
- off-time (s)	ŀ	153	
Number of avalog with augment (tatal)		360	
Number of cycles with current (total) Additional test of operational	922	1000	P
performance capability without	8.3.3.		, n
current for withdrawable circuit-	5.5		107
breaker			
Number of operations cycle		100	
After test, the isolating contacts,		100	P
withdrawable mechanism and interlocks			
The test results contained in this report solution			P



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 15, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
shall be suitable for further service				
Verification of dielectric withstand	8.3.3.			
- equal to twice the rated operational		1380 V		
voltage with a minimum of 1000 V		Leakage current <0,01 mA		P
- no breakdown or flashover		Econogy current 10,01 mm		
Verification of temperature-rise	8.3.3.			
Test current Ie (A)		4000		
Temperature rise of main circuit terminals <=80 K (K)		See table: temperature	rise measurement	P
Verification of overload releases	8.3.3. 7			
Test current 1,45 times the value of their current setting at the reference temperature (A)		5800)	
Conventional tripping time <2h when In > 63 A (s)		1h 1 m	in	Р
Verification of undervoltage and shunt releases	8.3.3. 8			
Test made at room temperature. Shunt release shall operate at 70% of the minimum rated control supply voltage (V):		154		P
Test sequence II/III (Ics=Icu)	8.3.4	101		
Sample no Rated current: In (A) Rated operational voltage: Ue (V) Rated ultimate short-circuit breaking capacity (kA):		#002 4000 400		
The circuit-breaker is mounted complete on its own support Test made in free air The characteristics of the metallic screen: - perforated metal - ratio hole area/total area - size of hole (mm²) Finish: conductive plating Fusr "F": copper wire diameter/long Circuit is earthed at supply-star Conductor cross-sectional area (mm²): Line connected at underside Tightering torques (Nm): Test sequence of operation: O = t =		0,5 29 120 14,0		
Test sequence of operation: O – t – CO – t – CO				

The test results contained in this report relate only to the Item(s) tested. Total or partial copying of test report is forbidden without permition of Testing laboratory RMC "Test center".



RESEARCH AND MANUFACTURING COMPLEX

"TEST CENTER" (RMC "Test center") Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 16, total amount:26

Requirement - Test		Clause	Result - Remark	Verdict	
Test voltage $U/Ue = 1,05 (V)$			No.		
	L1:		428,	1	
	L2:		428,	2	
	L3:		428,		
R.m.s. test current AC/DC: (kA)		211-			
	L1:		101,	0	
	L2:		102,		
	L3:		102,		
Power factor/time constant:	шэ.		0,17		
Factor "n"			2,2		
			-		
Peak test current (kA): Test sequence "O"			227,	0	
Max. let-through current (kApeak):	T 4		0 7 4		
	L1:		35,45		
	L2:		33,67		P
	L3;		12,61	14	
Joule integral I ² dt (kA ² s):					
	L1:		152	9	
	L2:		151	6	P
	L3:		132		
Pause, t (min):			3		
Test sequence "CO"					
Max. let-through current (kApeak):	1				
wax. let unbugh current (Kripoux).	L1:		33,22	20	
	L2:		16,30		P
	L3:		-		Γ
I 1 - 1 1 T2 14 (1- A 2-)	LD,		33,46)9	
Joule integral I ² dt (kA ² s):	T 1		100		
	L1:		189		in.
	L2:		603		P
	L3:		142	0	
Pause, t (min):			3		
Test sequence "CO"					
Max. let-through current (kApeak):					
· - _ /	L1:		31,53	32	
	L2:		34,18		P
	L3:		14,22		
Joule integral I ² dt (kA ² s):			2		
<i>5</i>	L1:		117	4	
	L2:		187	1	P
	L3:		492	11	25
Melting of the fusible element	100.		+32	•	P
Damage to insulation on conductors					P
					1
Holes in the PE-sheet for test sequer					

The test results contained in this report relate only to the Item(s) tested. Total or partial copying of test report is forbidden without permition of Testing laboratory RMC "Test center".



RESEARCH AND MANUFACTURING COMPLEX
"TEST CENTER" (RMC "Test center")
Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108

Test report № 015.12CV-20 Page 17, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
"0"				P
Cracks observed				P
Oscillograms		See table: "Osc	illograms"	
Additional requirements for circuit- breakers with electronic over-current protection	An. F			
Immunity tests	F.4			
Sample number Rated current: In (A) Rated operational voltage: Ue (V) Rated control supply voltage of secondary circuits: Uc (V)		#003 4000 AC69 AC23	0	
Harmonic currents	F.4.1			
Non tripping time (10x tripping time at 2Ir) t1 (s): Conventional time t2 (s): Tripping time t3=0,9x tmin at 2Ir (s): Tripping time t4=1,1x tmax at 2Ir (s): Rated frequency (Hz) Test of option		84 (t1=1 7200 6,43 10,6 50 B		P
Test current 0,95x1,05xIr (true r.m.s) (A): Amplitude of third harmonic >60% Amplitude of fifth harmonic >14% Amplitude of seventh harmonic >7% Peak factor lp/lrms >=2,1 No tripping t>=t1 (s)		1600 (Ir1= 68% 17% 7,5% 2,1 84	,	P
Test current 1,05x1,3xIr (true r.m.s) (A): Amplitude of third harmonic >60% Amplitude of fifth harmonic >14% Amplitude of seventh harmonic >7% Peak factor lp/lrms >=2,1 No tripping t<=t2 (s)		2180 68% 17% 7,5% 2,1 17		P
Test current 2xIr (true r.m.s) (A): Amplitude of third harmonic >60% Amplitude of fifth harmonic >14% Amplitude of seventh harmonic >7% Peak factor lp/lrms >=2,1 No tripping t3<=t<=t4 (s) Current dips Maximum tripping time at 2xIr (s) Test duration (s)	F4.2	3200 68% 17% 7,5% 2,1 9		P
Test dulation (s) Test no 1 with Io=0 and Δt=0,5T No tripping		35 No		P



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 18, total amount:26

Requirement - Test	Clause	Result - Remark Verdict	10 ===
Test no 2 with Io=0 and Δt=1T			
No tripping		No	P
Test no 3 with Io=0 and Δt=5T			
No tripping		No	P
Test no 4 with Io=0 and Δt=25T			
No tripping		No	P
Test no 5 with Io=0 and Δt=50T			
No tripping		No	P
Test no 6 with Io=0,4xIr and Δt =10T			
No tripping		No	P
Test no 7 with Io=0,4xIr and Δt=25T			
No tripping		No	P
Test no 8 with Io=0,4xIr and Δt=50T			
No tripping		No	P
Test no 9 with Io=0,7xIr and Δt=10T			
No tripping		No	P
Test no 10 with Io=0,7xIr and Δt=25T			
No tripping		No	P
Test no 11 with Io=0,7xIr and Δt=50Γ			
No tripping		No	
Electrostatic discharges	F4.3		P
Discharge test voltage		8 kV	P
Polarity of discharges		Positive/negative	P
Electrical fast transients/bursts	F4.5		
(EFT/B)			
Test level of power port		4kV/2,5 kHz	,
Surge	F4.6		
Test level of power port Ue>=100 Va.c		6 kV line to earth	P
, <u>, , , , , , , , , , , , , , , , , , </u>		3 kV line to line	
Conducted disturbances induced by	F4.7		
radio-frequency fields (common			
mode)			
Test level of power port		10 V/m (0,15 to 80 MHz with 80% AM	P
		at 1 kHz)	_
Emission tests	F.5	,	
Radiated RF disturbances (30 MHz -	F5.4	7 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	
1 GHz)			
CISPR 11/CISPR 22			P
Dry heat test	F.7		-
Test chamber temperature		40°C	
Test duration		168h	
No tripping of the circuit-breaker shall	F7.2	2002	1
occur			P
No operation of the electronic controls			



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108

Test report № 015.12CV-20 Page 19, total amount:26

Requirement - Test	Clause	Result - Remark Verdict	- 20
which could cause the circuit-breaker to			P
trip occur			
Verification of overload releases	F7.3		
Ambient air temperature		30°C	
Minimum current setting (A):		1600	
Minimum time setting at 1,5xIr (s):		15	
Conventional non tripping current			
1,05xIr (A):		1680	
No tripping time (s):		>2h	P
Conventional tripping current 1,3xIr			
(A):		2080	
Tripping time (s):		15	P
Maximum current setting (A):		4000	
Minimum time setting at 1,5xIr (s):		15	
Conventional non tripping current			
1,05xIr (A):		4200	
No tripping time:		>2h	P
Conventional tripping current 1,3xIr			
(A):		5200	
Tripping time (s):		17	P
Damp heat test	F.8	•	
Upper temperature	1.0	55°C	P
Number of cycles		6	P
Verification of overload releases	F8.2	0	
Ambient air temperature	10.2	28°C	
		1600	
Minimum current setting (A):		15	
Minimum time setting at 1,5xIr (s):		13	
Conventional non tripping current		1690	
1,05xIr (A):		1680	D
No tripping time:		>2h	P
Conventional tripping current 1,3xIr		2000	
(A):		2080	
Tripping time (s):		17	P
Maximum current setting (A):		4000	
Minimum time setting at 1,5xIr (s):		15	
Conventional non tripping current			
1,05xIr (A):		4200	_
No tripping time (s):		>2h	P
Conventional tripping current 1,3xIr			
(A):		5200	
Tripping time (s):		15	P
Temperature variation cycles at a	F.9		
specified rate of change			
Maximum test chamber temperature:		80°C	
Rate of change of temperature:		1K/min±0,2K/min	

The test results contained in this report relate only to the Item(s) tested. Total or partial copying of test report is forbidden without permittion of Testing laboratory RMC "Test center".



RESEARCH AND MANUFACTURING COMPLEX

"TEST CENTER" (RMC "Test center") Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108

Test report № 015.12CV-20 Page 20, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict
Duration of exposure at maximum			
temperature:		2h	
		-25°C	
Minimum test chamber temperature:		1K/min±0,2K/	min
Rate of change of temperature:			
Duration of exposure at minimum			
temperature:		2h	
Number of cycles:		28	
No operation of the electronic controls	F9.3		
which could cause the circuit-breaker to			P
trip occur			
Verification of overload releases	F9.4		
Ambient air temperature		28°C	
Minimum current setting (A):		1600	
Minimum time setting at 1,5xIr (s):		15	
Conventional non tripping current			
1,05xIr (A):		1680	
No tripping time:		>2h	P
Conventional tripping current 1,3xIr			
(A):		2080	
Tripping time (s):		16	P
Maximum current setting (A):		4000	
Maximum time setting at 1,5xIr (s):		15	
Conventional non tripping current			
1,05xIr (A):		4200	
No tripping time (s):		>2h	P
Conventional tripping current 1,3xIr			
(A):		5200	
Tripping time (s):		17	P
Individual pole short-circuit test	An. H		
sequence			
Test of individual pole short-circuit	H.2		
breaking capacity			
Sample no		#004	
Rated current: In (A)		4000	
Rated operational voltage: Ue (V)		AC400	
Rated ultimate short-circuit breaking			
capacity (kA):		100	
The circuit-breaker is mounted complete			
on its own support			
Test made in free air			
The characteristics f the metallic screen:			
- perforated metal			
- ratio hole area/total area		0,45-0,65	
- size of hole The test recently contained in this report relate	111	<30 mm ²	



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 21, total amount:26

Requirement - Test		Clause	Result - Remark	Verdict	
Finish: conductive plating					
Fusr "F": copper wire diameter/long			0,8mm	/50mm	
Circuit is earthed at load-star					
Conductor cross-sectional area (mm ²):		4x10	0x10	
Line connected at underside					
Tightering torques (Nm):			14	,0	
Test circuit according figure 9					
Test voltage U/Ue=1,05 (V)	1				
	L1:		43	6	
	L2:		43	6	
	L3:		43	6	
R.m.s. test current (kA):			50	,2	
Power factor/time constant			0,2	24	
Peak test current (kAmax):			10	7	
Test sequence "O' L1					
- max. let-through current (kApeak)			10	1	P
- Joule integral I ² dt (MA ² s)		V-C	71	,6	
Pause t (min):			3		
Test sequence "CO' L1					
- max. let-through current (kApeak)			77	.5	P
- Joule integral I ² dt (MA ² s)			43		
Test sequence "O' L2					
- max. let-through current (kApeak)			96	.8	P
- Joule integral I ² dt (MA ² s)			65	´	
Pause t (min):			3		
Test sequence "CO' L2					
- max. let-through current (kApeak)			72	.7	P
- Joule integral I ² dt (MA ² s)			42		
Test sequence "O' L3					
- max. let-through current (kApeak)			75	.0	P
- Joule integral I ² dt (MA ² s)			64	· I	î
Pause t (min):			3		
Test sequence "CO' L3					
- max. let-through current (kApeak)			73.	.5	P
- Joule integral I ² dt (MA ² s)			46		•
Melting of the fusible element			Ne		P
Holes in the PE-shield for test sequer	ice		111	_	•
"O":			N)	P
Cracks observed	I		Ne		P
Verification of dielectric withstand		H.3			
- equal to twice of the rated operation	al				
voltage with a minimum of 1000 V (100	00	P
- no breakdown or flashover			<0,02		P
Verification of overload releases	10	H.4			



RESEARCH AND MANUFACTURING COMPLEX

"TEST CENTER" (RMC "Test center")
Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032
Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108


Test report № 015.12CV-20 Page 22, total amount:26

Requirement - Test	Clause	Result - Remark	Verdict	
The operation of overload releases shall				
be verified at 2,5 times the value of their				
current setting on each pole separately				
(A):		4000 (In	r1=0,4In	
Time specified by manufacturer at 2		N	1	
times the value of current setting (s):		<=9,66	(t1=15s)	
Operation time (s):			7	
L1:			5	>
L2:			5	P
L3:			4	

TABLE: temperature rise masurements					
Thermocouple locations	Max. temperature measured (°C)			Max. temperature limit (°C)	
#01	L1	L2	L3		
Upper terminal	62	79	66	80	
Lower terminal	62	75	64	80	
Handle	3			25	
Enclosure	4			40	
Back	7			50	





Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report № 015.12CV-20 Page 23, total amount:26





Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report № 015.12CV-20 Page 24, total amount:26





Product: ACB Type: 3P/4000A Sequence: CO 101.9/227.0kA

 $\cos \Phi$: 0.170

Ut: 428.3V

I_P A=33.220kA Ip B=16.360kA I_p C=33.469kA


I2t A=1.898MAAS 12t B=603.0kAAS I2t C=1.420MAAS

T_{mb} A=7.160mS T_{mb} B=7.120mS T_{mb} C=2.380mS

Trac A=6.732mS Trac B=2.146mS T_{rac} C=2.095mS



Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report № 015.12CV-20 Page 25, total amount:26



-test case does apply to the test object: N/A
-test object does meet the requirement: P
-test object does not meet the requirement: F



"TEST CENTER" (RMC "Test center") Registered address: 1 Zhukovskoho str., Vinnytsia city, 21032 Actual address.: 69096, c.Zaporizhzhia, str. Borodinska, 108 Test report
№ 015.12CV-20
Page 26, total amount:26

5. RESULT:

BA50-47 4000H40 3H M11C11S11 39U00, conform the requirements of EN 60947-1:2007/A2:2014, EN 60947-2:2017/A1:2020, EN 60947-3:2009/A1:2012. Requirements of Normative documents, which are reflected in test report, are not expended to the test sample.

	161	
Testing engineer:	- Surf	—— Huz Yevhen.